

 MICROELETTRICA SCIENTIFICA MILANO ITALY	Addendum Operation Manual IM30-AR	Doc. N° MO-0097-ING
		Rev. 0 Pag. 1 of 1

The setting range of the following parameter has changed

12. PROGRAMMING

12.1 - PROGRAMMING OF FUNCTIONS SETTINGS

Display	Description	Setting Range	Step	Unit
I> .5In	Trip level of low-set overcurrent element (p.u. of the rated current of the phase C.Ts.)	0.25 - 4 - Dis	0.01	In

0	EMISSION	03-02-99	P. Brasca	D. ABAD	
REV.	DESCRIPTION	DATE	PREP.	CONTR.	APPR.